

April 8, 2005

Mike:

I have reviewed the Chapel Ridge Phase 2A plans (sealed on March 3, 2005) for conformance with the County Water Standards and Specifications for Waterlines at the time the Chapel Ridge PUD was approved in 2003. The proposed C-800 PVC and DIP materials indicated on your plans are acceptable. It is my understanding that this project will be permitted and operated by Heater Utilities. Our approval of your submission does not absolve you of any requirements associated with Heater Utilities.

Sincerely,

A handwritten signature in black ink, appearing to read 'Will Baker', with a long horizontal flourish extending to the right.

Will Baker, Chatham County Public Works Department