


CHATHAM COUNTY WATER UTILITY

UTILITIES - A Division of Public Works

- Maintenance and Construction
- Water Treatment Plant
- Wastewater Treatment Plant
- Billing and Collections



POST OFFICE BOX 910
PITTSBORO, N. C. 27312-0910

ORGANIZED 1770

707 SQUARE MILES

PHONE
(919) 542-8270

FAX
(919) 542-8282

To: John Harris

Re: Windfall Creek Plan Approval

Dear John,
Chatham County Utilities Division has reviewed the plans you have submitted for the Windfall Creek Project and hereby approves the plans with the stipulations we discussed as far as to the addition of Hydrants and Valves.
All materials and installation specifications are to be approved by the utilities Director as well as a pre-construction meeting to be held before construction begins.

Sincerely,

Will Baker
Utilities Director




This paper is made from recycled waste.

CHATHAM COUNTY WATER UTILITY

UTILITIES - A Division of Public Works

- Maintenance and Construction
- Water Treatment Plant
- Wastewater Treatment Plant
- Billing and Collections



POST OFFICE BOX 910
PITTSBORO, N. C. 27312-0910

ORGANIZED 1770

707 SQUARE MILES

PHONE
(919) 542-8270

FAX
(919) 542-8282

To: John Harris, P.E.
Re: Windfall Development

Dear John,

This letter is to inform you that the Chatham County Utilities Division has reviewed your plans for the Windfall Subdivision.

The Utilities Division hereby approves your plans with the addition of the following items.

Below is a list of locations in which there will need to be in line valves added on the Windfall Dr. water main at the intersections and on the Bigwoods Drive water main.

Please note that all the valves to be added inside the development are on the Windfall Drive water main and will need to be installed to provide isolation from all sides if the development were ever to tie into other feeds and become a loop.

Please note that there shall be an inline valve a minimum of every 1000ft. on the Bigwoods Dr. Water main.

BIGWOODS DRIVE VALVE ADDITION LOCATIONS

PT STA. - 0+00

PT STA. - 20+00

PT STA. - 38+00

PT STA. - 50+00

PT STA. - 60+00

PT STA. - 80+00

All valves on Bigwoods Rd. shall be located in proximity to the fire hydrant valves.



This paper is made from recycled waste.

WINDFALL DRIVE VALVE ADDITION LOCATIONS

PT STA. - 4 + 80.52

PT STA. - 16 + 00

PT STA. - 32 + 43.67

PT STA. - 48 + 80.52

I would like to schedule a pre-construction meeting with the contractor and a representative from your office at least 48hrs. prior to construction.

I would also like to be informed a minimum of 24hrs. before any taps are made onto existing water mains and have one of our inspectors present for the pressure testing of the tapping sleeve and receive the coupon from the tap to insure the proper tap size was achieved.

If you have any questions please feel free to contact me at (919)-542-8238 or e-mail me at : will.baker@ncmail.net

Sincerely,

A handwritten signature in dark ink, appearing to read 'Will Baker', with a long horizontal flourish extending to the right.

Will Baker
Utilities Director

State of North Carolina
 Department of Environment and Natural
 Resources
Division of Environmental Health
Public Water Supply Section



Michael F. Easley, Governor
 William G. Ross, Jr., Secretary
 Linda C. Sewall, Director
 Jessica G. Miles, Section Chief

North Carolina Public Water Supply

Plan Review Tracking System

This information is current as of: 5/11/2005

Plan Information	Applicant Information	Engineer Information
Year Submitted: 2005 County: CHATHAM Tracking No.: 05-00719 WINDFALL S/D Type: WATER MAIN EXTENSION Pws ID: 03-19-126 CHATHAM CO WATER SYSTEM	CHARLIE HORNE P O BOX 1550 PITTSBORO , NC 27312	JOHN W HARRIS, PE 7909 OCOEE COURT RALEIGH , NC 27612

For projects received on or after May 1, 2005 contact:

Name	Email Address	Phone
HENRY OU	HEINRICH.OU@NCMAIL.NET	919-715-3226

For projects received prior to May 1, 2005, Identify the review engineer from the initials in the comments column below and contact that engineer.

<i>Initials</i>	<i>Review Engineer</i>	<i>E-mail address</i>	<i>Phone Number</i>
TCC	Tony Chen	tony.chen@ncmail.net	919/715-3231
SMC	Siraj Chohan	siraj.chohan@ncmail.net	919/715-3235
DEN	Doug Newhouse	douglas.newhouse@ncmail.net	919/715-3234
OU	Henri Ou	heinrich.ou@ncmail.net	919/715-3226
SLO	Sandy O'Daniel	sandy.odaniel@ncmail.net	919/715-3269

For projects with initials other than those shown above or with no initials, contact either Tony Chen or Public Water Supply Section at 919/733-2321.

Activity Date	Activity Description	Comments
5/11/2005	APPROVED PROJECT MAILED	
5/9/2005	DATE OF AUTH TO CONSTRUCT	TCC BY SEP
5/4/2005	WSMP ON FILE - COMPLETE	WSMP #99-02125
5/4/2005	DATE OF APPROVAL	
4/27/2005	DATE RECEIVED	

Please [click here](#) to review the status of another plan.

Please [click here](#) to return to Public Water Supply main menu.