


FAX COVER SHEET



**NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES**

Raleigh Regional Office
1628 Mail Service Center
Raleigh, NC 27699-1628

3 Pages, including cover sheet

TO: Christopher Sandt, EIT

FAX: 919-361-2269

FROM: Larvin Pageau

DATE: 9-21-05

SUBJECT: BRIAR CHAPEL PHASE 1 E+SC APPROVAL

MESSAGE:


CALL IF QUESTIONS. THANKS!

If you do not receive all pages, call 919.791.4200 or fax back to 919.571.4718.

**PLEASE NOTE OUR PHONE NUMBER HAS CHANGED
THE FAX NUMBER REMAINS THE SAME**

**State of North Carolina
Department of Environment
and Natural Resources
Raleigh Regional Office**

**Michael F. Easley, Governor
William G. (Bill) Ross, Secretary**



**DIVISION OF LAND RESOURCES
LETTER OF APPROVAL**

September 15, 2005

NNP-Briar Chapel, LLC
31 Hillsboro Street
Pittsboro, NC 27312
ATTN: Ed Timoney

RE: Project Name: Briar Chapel Ph 1
County: Chatham
Submitted by: Teh John R. McAdams Co
Date Received: 9/01/05; 9/16/05
Date Processing Initiated: 9/16/05
Watershed: Cape Fear #1/03-06-06
New Submittal (X) Revised ()

Dear Mr. Timoney:

This office has reviewed the subject Erosion and Sedimentation Control Plan. We find the plan to be acceptable and hereby issue this letter of approval. If any modifications, performance reservations, or recommendations are applicable, a list is enclosed and is incorporated as a part of this letter of approval. The enclosed Certificate of Approval should be posted at the job site. In addition, it should be noted that this plan approval shall expire three (3) years following the date of approval, if no land-disturbing activity has been undertaken, in accordance with Title 15A, North Carolina Administrative Code (NCAC) 4B.0029.

If any modifications are not incorporated into the plan and implemented in the field, the site will be in violation of the Sedimentation Pollution Control Act of 1973 (North Carolina General Statute (NCGS), 113A-61.1).

15A NCAC 4B.0018(a) requires that a copy of the approved plan be on file at the job site. Also, this letter gives the notice required by NCGS 113A-61.1(a) concerning our right to perform periodic inspections to ensure compliance with the approved plan.

North Carolina's sedimentation pollution control program is performance oriented, requiring protection of the natural resources and adjoining properties. If at any time during this project it is determined that the Erosion and Sedimentation Control Plan is inadequate to meet the requirements of the Sedimentation Pollution Control Act of 1973 (NCGS 113A-51 through 66), this office may require revisions in the plan and its implementation to ensure compliance with the Act.

Ed Timoney
September 15, 2005
Page 2


Acceptance and approval of this plan is conditioned upon your compliance with applicable federal and state water quality laws, regulations and rules. This could include the Division of Water Quality under stormwater or other specific water quality standards, and the U.S. Army Corps of Engineers under Article 404 jurisdiction. Our approval does not supersede any other required permit or approval.

Since this project disturbs one or more acres, one such approval relates to the stormwater that will discharge from your project. This runoff is permitted pursuant to the National Pollutant Discharge Elimination System (NPDES) administered in North Carolina by the Division of Water Quality (DWQ). Attached is the General Stormwater NPDES Permit, NCG010000, as revised October 1, 2001, covering your activity. You are responsible for complying with the General Permit requirements and are subject to enforcement by DWQ for any violations of the General Permit.

Please note that this approval is based in part on the accuracy of the information provided concerning financial responsibility. You are requested to file an amended Financial Responsibility Form if any changes become necessary. In addition, it would be helpful if you would notify this office when the proposed land-disturbing activity covered by this plan is initiated.

Your cooperation is appreciated and we look forward to working with you on this project. If there are any questions, please do not hesitate to contact this office.

Sincerely,



Karyn Pageau, EIT
Asst. Regional Engineer
Land Quality Section

KP:clm

cc: Christopher Sandt, The John R. McAdams Co.
Mr. Ken Schuster, P.E., Division of Water Quality

Ed Timoney
 September 15, 2005
 Page 3

PLAN REVIEW COMMENTS

| | |
|---------------------------------|--|
| PROJECT NAME: Briar Chapel Ph 1 | DATE RECEIVED: 9/16/05; 9/01/05 |
| LOCATION: Chatham County | REVIEWED BY: JI/KP |
| New Submittal (X) Revised () | Approved (X) Disapproved () |
| Reasons for Disapproval () | Modifications (X) Performance Reservations () |

- 1) Change Dissipator Thickness for Culvert R from 22" to 27" due to Rock Riprap, Class 2 being utilized.
- 2) Modify construction sequence to stipulate that before any measures can be removed, all associated drainage areas must be stabilized regardless of phasing installation. Measures from previous phases will remain at design dimensions until associated drainage area is stabilized.
- 3) Provide one copy of drawings revised as a result of requested changes to this office prior to construction beginning or October 15, 2005 whichever is sooner.

RECOMMENDATIONS AND/OR COMMENTS: