

5/15/06

Bruce Curt's  
% ENT Surveying

RE: Crows Creek

Dear Bruce,

Enclosed is the preliminary soils map for the project known as Crows Creek. All lots are shown with adequate area of 24" soil for onsite systems. The soil is characterized as having a 8-12" sandy loam underlain by a sandy clay loam to clay Bt.

I will proceed with the lot by lot evaluation to finalize the lot lines.

Sincerely,

Neal Floyd  
Soil Scientist



1035  
 222  
 10-24  
 Prov. suitable



ENT  
 Land Surveyor Seal

