

Angela Birchett

From: Wendy Paschal [wendy.paschal@ncmail.net]
Sent: Friday, July 21, 2006 1:44 PM
To: 'Birchett, Angie'
Subject: Cooper Property/Contentnea

Angie,

Because of the under sizing of the water line and wrong material used in Windfall Creek, we had a meeting with their attorney, Gray Styers, and the developer, Jonna Butcher. Per our discussion during that meeting it was agreed that they will install a PRV (pressure reducing valve) at the entrance of Windfall Creek where it connects to Big Woods Rd. We are conducting a hydraulic study to see what size main is needed from the end of Windfall Creek where it enters Hatley Rd to Mt. Gilead Ch. Rd and/or Bynum Ridge Rd. Upon completion of the hydraulic study we will forward the engineers comments to you.

Thanks,

Roy