



- MEMO
- TELEPHONE
- FIELD REPORT
- CALCULATIONS

LAND USE EVALUATION

CIVIL ENGINEERING

CONSTRUCTION MANAGEMENT

AUTHOR: MPA

DATE: 8/11/2006 TIME: _____

PROJECT: County Line Plaza CLIENT: Lee-Moore Oil Company

SUBJECT: Wastewater Generation Projections PROJECT NO.: 100-08

Projected Wastewater Flow Rates		GPD		
1)	Retail (49,400 SF) @ 0.15 GPD / SF	7410		
2)	Outparcel C Store w/ Grill @ 2,500 GPD	2500		
3)	Outparcel Drug Store @ 500 GPD	500		
4)	Home Improvements Store	3200		
		13610	GPD	
Utilize 14,000 GPD as basis of Preliminary Wastewater System Design				

