

NC DOT

APPROVAL



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
DIVISION OF HIGHWAYS

MICHAEL F. EASLEY,
GOVERNOR

LYNDO TIPPETT
SECRETARY

April 5, 2007

Chatham County

Subject: Subdivision - Plan Review - Briar Chapel Great Ridge Parkway North

Mike Sanchez, PE
The John R. McAdams Co., Inc
PO Box 14005
Research Triangle Park, NC 27709-4005

Dear Mr. Sanchez:

The N. C. Department of Transportation, Division of Highways District Office has reviewed the construction plans as submitted to this office for the subject subdivision. In order for final approval the following items must be corrected and revised plans submitted to this office for review:

1. A driveway permit would be required for the proposed connection to Mann's Chapel Road (SR 1532).
2. Any comments/redlines from the Hydraulics and Structures Units shall be addressed.
3. Appropriate sight distance triangles shall be shown at every intersection.
4. Typical sections showing pavement structure for crossovers shall be on plans.
5. Shoulder sections should be 8' on fill sections and 6' on cut sections.
6. All centerline markings shall be yellow.
7. Alignment of intersections at the gore areas are not appropriate. These intersections shall be a minimum of 100' from where the divided highway begins or ends.

These items and the items redlined on the attached shall be changed and submitted to this office for final review.

The Horizontal and Vertical alignment is approved for the main line portion of Great Ridge Parkway North.

If you have any further questions regarding this matter, please do not hesitate to call this office at (336) 629-1423.

Yours truly,

A handwritten signature in black ink, appearing to read "Reuben Blakley".

Reuben Blakley, PE
District Engineer

Attachments

cc: Jim Johnson, PE, Division Engineer
 File

P.O. Box 1164, Asheboro, North Carolina 27204
Phone (336) 629-1423 Fax (336) 629-7228