



CHATHAM COUNTY PUBLIC HEALTH DEPARTMENT
Division of Environmental Health
Soil Erosion and Sedimentation Control

April 4, 2007

LETTER OF APPROVAL WITH MODIFICATIONS

NNP Briar Chapel, LLC
5850 Fayetteville Road, suite 201
Durham, NC 27713

RE: Project Name: Briar Chapel-Great Ridge Parkway
Project Number: 2007-019
Acres approved: 20.39
Total Acres: 1649
Submitted By: The John R. McAdams Company
Date Received: 3-12-07

Dear Sir or Madam:

This office has reviewed the subject erosion and sedimentation control plan. We find the plan to be acceptable with modifications and hereby issue this letter of Approval With Modifications. The Modifications Required for Approval are listed on the attached page. This plan approval shall expire two (2) years following the date of approval, if no land-disturbing activity has been undertaken.

Please be advised that Section 6 (I) of the Chatham County Sedimentation and Erosion Control Ordinance requires that a copy of the approved erosion control plan be on file at the job site. Also, you should consider this letter to give the Notice required by G.S. 113A-61.1(a) of our right of periodic inspection to insure compliance with the approved plan.

North Carolina's Sedimentation Pollution Control Program is performance-oriented, requiring protection of existing natural resources and adjoining properties. If, following the commencement of this project, it is determined that the erosion and sedimentation control plan is inadequate to meet the requirements of the Chatham County Sedimentation and Erosion Control Ordinance, this office may require

revisions to the plan and implementation of the revisions to insure compliance with the Act.

Acceptance and approval of this plan is conditioned upon your compliance with Federal and State water quality laws, regulations, and rules. In addition, local city or county ordinances or rules may also apply to this land-disturbing activity. This approval does not supersede any other permit or approval.

Please be aware that your project will be covered by the enclosed NPDES General Stormwater Permit NCGO1000 (Construction Activities). You should first become familiar with all of the requirements for compliance with the enclosed general permit.

Please note that this approval is based in part on the accuracy of the information provided in the Financial Responsibility Form, which you have provided. You are requested to file an amended form if there is any change in the information included on the form. Please notify us when you would like to schedule a preconstruction conference. Notification shall be given at least 7 days prior to initiation of activity.

*****This approval is contingent on the receipt of plans revised as per the attached comments by Friday, April 13, 2007. If revised plans are not received by that time, this approval letter will be rescinded. The land disturbing permit will be issued upon review and approval of the revised plans. *****

Your cooperation is appreciated.

Sincerely,

Jim Willis, CPESC
Chatham County Soil Erosion Control Officer

Enclosures: Certificate of Approval
NPDES Permit

MODIFICATIONS REQUIRED FOR APPROVAL

1. Provide diversions for the runoff to be directed into all appropriate sediment traps.
2. Include a temporary sediment trap at the southeast corner of culvert I for the initial clearing conditions.
3. Include temporary sediment traps at the four corners of culvert G.
4. Include a temporary sediment trap at the northeast corner of culvert F.