



May 11, 2007

Steve Yuhasz, PLS
ENT Land Surveys, Inc.
226 S. Churton Street
Hillsborough, NC 27278

Re: Arcadia Subdivision, Chatham County
Existing CMP driveway culvert

Dear Steve:

We were asked to evaluate an existing driveway culvert located on the property that is proposed as Arcadia Subdivision in Chatham County. The property is located on Lamont Norwood Road. The existing corrugated metal pipe is functioning properly today based on a visual inspection. The existing pipe is under a driveway that will serve proposed lots S2-10 and S2-11. The pipe should be adequate for construction traffic expected for construction of the houses on these 2 lots.

Please do not hesitate to contact us if we can provide any additional information on this matter.

With best regards,

Warren D. Mitchell, PE

