

Date	Time	Location	# of Lights	Average of Readings 24 fc or Less Required	# of lights	Notes	Fixture Compliance	Ordinance Compliance
		Maxi Mart Old US #1 Merry Oaks	8	9.35 fc	12 lights	3 lights not burning	no	
10/25/2007	7:24pm							
10/24/2007	7:52pm	Ray's Super Market Old #1 Moncure	8	17.28 fc	4 lights	All lights burning	no	
10/24/2007	8:01 PM	Jordan Dam Mini Mart Moncure	8	13.33 fc	12 lights	All lights burning	no	
10/24/2007	8:23pm	Mobil Lake Mart 64 East	10	25.4 fc	26 lights	1 not burning	no	
10/24/2007	8:38 PM	Top's 64 East	10	29.3 fc	18 lights	All lights burning	no	
10/24/2007	8:53 PM	M&R Shop Quick 15-501 North	9	34.1 fc	30 lights	1 light not burning	no	
10/24/2007	9:08 PM	Eagles 15-501 North Cole Park	11	23.3 fc	20 lights	All lights burning	yes	Yes
10/24/2007	9:18 PM	Petro Mart 15-501 North Cole Park	8	25.9 fc	12 lights	1 not burning	no	
10/24/2007	9:25 PM	Pantry 15-501 North Cole Park	10	44.9 fc	24 lights	All lights burning	no	
10/29/2007	6:52 PM	Wilsonville Store Us 64 East	8	50.7 fc	18 Lights	All Burning	no	
10/29/2007	6:52 PM	Wilsonville Store US 64 East #2	8	26.0 fc	4 Lights	All Burning	no	
10/29/2007	7:44 PM	Craigs Store Hwy 751 North	14	43.5 fc	20 Lights	2 Lights not burning	no	
10/29/2007	7:25 PM	Seagroves Supply Hwy 751 North	10	36.0 fc	8 Lights	1 not burning 3 dim	no	
10/29/2007	7:46 PM	G R Farrels RPR# 1008	8	23.0 fc	8 Lights	2 lights not burning	no	
10/29/2007								
10/29/2007	8:21 PM	Frosty's Store Jones Ferry Rd.	8	6.9 fc	4 Lights	1 not burning	no	
11/5/2007	5:47 PM	Community Store Brickhaven	10	8.0 fc	4 Lights	All lights burning	no	
11/5/2007	6:55 PM	Galaxy Gas S. Main Goldston	10	8.2 fc	8 Lights	1 not burning	no	
11/14/2007	6:09 PM	RBC Centura Bank @ Gov. Club	15	40.5 fc	6 Lights	All Burning	yes	
11/14/2007	6:17 PM	Governor's Village Apts.	8	3.2 fc	8 Lights	All Burning	yes	Yes
11/14/2007	6:21 PM	Governor's Village Apts. Carwash	8	8.0 fc	4 Lights	1 not Burning	no	
11/14/2007	6:24 PM	Carolina Meadows Main Canopy	8	14.3 fc	8 Lights	All Burning	yes	Yes
11/14/2007	6:24 PM	Carolina Meadows "Health Center"	8	2.7 fc	6 Lights	All Burning Not full cutoff	yes	Yes
11/14/2007	6:33PM	Carolina Meadows " The Fairways"	8	8.2 fc	2 Lights	2 bulbs each no sheilds	no	
11/14/2007	6:45 PM	SECU Cole Park	17	26.7 fc	15 Lights	All Burning (recessed)	yes	
11/14/2007	6:53 PM	CVS Chatham Crossing	9	33.3 fc	12 Lights	1 not Burning	yes	
11/14/2007	7:03 PM	Wachovia ATM @ Chatham Crossing	3	20.0 fc	2 Lights	All Burning	yes & no	Yes
11/14/2007	7:06 PM	Bank of America ATM @ Chatham Crossing	0	0.00 fc	2 Lights	Lights not working		
11/14/2007	7:12 PM	First Citizen @ Chatham Downs "NEW"	12	32.7 fc	8 Lights	All burning	yes	
11/14/2007	7:26 PM	Galloway Ridge Entry canopy	13	26.2 fc	6 Lights	All Burning	yes	