


CHATHAM COUNTY WATER UTILITY

UTILITIES - A Division of Public Works

- Maintenance and Construction
- Water Treatment Plant
- Wastewater Treatment Plant
- Billing and Collections



PHONE
(919) 542-8270

FAX
(919) 542-8282

POST OFFICE BOX 910
PITTSBORO, N. C. 27312-0910

ORGANIZED 1770

707 SQUARE MILES

December 12, 2007

Matt Collins, EI
Development Consulting Services, Inc.
1401 Aversboro Road, Suite206
Garner, NC 27529

Re: Parker Springs

Dear Mr. Collins:

Parker Springs will be beneficial to the county water system because of the installation of the 12 inch water main on Mt. Gilead Church Rd that will tie into the entrance to Parker Springs subdivision.

Within Parker Springs, there will be three utility easements that will tie into Monterrane Phase 1 & 3, Cooper Track and Windfall subdivision. The purpose of the 12 inch water main is to give adequate pressure to the subdivisions listed above and to create a loop system that will tie-in US 15-501 and BigWoods rd.

Currently, if there is a water outage the County will be unable to provide water in these subdivisions but if the 12 inch water main is installed and thru these subdivisions, the county will be able to feed from another direction and still be able to provide water without interruption.

Sincerely,

COUNTY OF CHATHAM

A handwritten signature in black ink, appearing to read 'Roy Lowder', written over a horizontal line.

Roy Lowder
Utilities Director



This paper is made from recycled waste.