

PLANNING & ZONING REVIEW NOTES

V. A.

Below are notes from last month's Planning Board meeting:

SUBJECT: Request by Parker Springs, LLC for subdivision preliminary plan approval of “**Parker Springs**”, consisting of 50 lots on 87 acres, located off SR-1700, Mt. Gilead Church Road, New Hope and Williams Township.

ATTACHMENTS: The following may be viewed on the Planning Department website at www.chathamnc.org under Planning, Rezoning & Subdivision Cases, 2008, Parker Springs, Prel:

1. Major Subdivision Application.
2. ArcView map, parcel #17425
3. Copies of Plat slide 99-218 and 2001-58
4. Preliminary soil report and map, prepared by Mitchell Environmental, P. A., dated January 9, 2008.
5. Wetlands and stream delineation prepared by Mitchell Environmental, P A, dated October 24, 2007.
6. Preliminary map titled “Parker Springs Subdivision”, prepared by Stancil & Associates, dated October 8, 2007, last revised December 6, 2007.

INTRODUCTION / BACKGROUND / PREVIOUS BOARD ACTIONS:

<u>Zoning:</u>	RA-40	<u>Water Source:</u>	Chatham County
<u>Watershed District:</u>	WSIV-Protected Area	<u>Septic:</u>	Individual – on-site & off-site
<u>Within 100 year flood plain:</u>	No		

The Board of County Commissioners approved the sketch design plan consisting of 50 lots on 87 acres on January 16, 2007 per minutes of said meeting which stated “After considerable discussion and as per the Planning Department and Planning Board recommendation, Commissioner Cross moved to grant sketch design approval of “Parker Springs Subdivision” with the following condition and with the environmental impact assessment with peer review prior to the preliminary plat approval:”

1. The park areas and off-site septic area within Monterrane Subdivision along the common boundary with the subject property shall be shown on the preliminary and final maps. *The park areas and off-site septic areas are shown on the preliminary map; however, ownership of these areas is not shown. Staff recommends the final plat, state ownership of the park and off-site parcels.*

Re: Parker Springs

INTRODUCTION / BACKGROUND / PREVIOUS BOARD ACTIONS

2. To include an environmental statement with peer review prior to preliminary plat approval. *At the January 16, 2007 BOC meeting, Grey Styers, attorney for the developer, offered to provide an environmental impact statement or study consistent with the County's Subdivision Regulations. At the time of sketch plan approval the Subdivision Regulations, Section 5.2 A (1), did not specify the threshold criteria required for an environmental impact and did not require a peer review of an environmental impact assessment. The environmental impact assessment has been submitted to Fred Royal, Environmental Resource Director, and is currently being reviewed by the Environmental Review Board (ERB). Comments from the ERB may be available for the March Planning Board meeting. A copy of the assessment can be viewed on the Planning Department website at www.chathamnc.org under Planning, Rezoning & Subdivision Cases, 2008, Parker Springs, Prel.*

ISSUES FOR FURTHER DISCUSSION AND ANALYSIS: The developer is requesting preliminary review for 50 lots to be accessed by a public, state maintained roadway off SR-1700, Mt. Gilead Church Road, south of Haw River Church. The roadways have been designed to the NCDOT hilly road standards. Dedication of public right-of-way has been provided to the adjoining properties of Cooper Family, LLC, parcel #17357, 130 acres; the Phillip Corn property, parcel # 17416, 63 acres; and to the Haw River Baptist Church property, parcel 62792 as shown on the preliminary plan. The Cooper property received a zoning approval on October 16, 2006 from the Board of County Commissioners for a Conditional Use RA-90 zoning district (previously a RA-5 zoning district) with a Conditional Use Permit for a 63 lot subdivision. The Corn property is zoned RA-5.

There are two (2) 60 foot wide, private easements within existing Monterrane Subdivision that connect to the subject property. See attachments 3. On sheet 2 of 3 of the preliminary plan, the developer shows a "60' R/W Dedication" between Lots 46 and 47 which connects to one of the private easements in Monterrane which is labeled "non-building, reserved by Monterrane, LLC and 20 foot public utility easement" as shown on Plat Slide 99-218. Staff recommends language on the final plat for Parker Springs state "Future public 60' R/W Dedication" to provide for a potential interconnecting road between developments if the private easement is changed to public in the future by the Monterrane homeowners. Per the Subdivision Regulations, "The future disposition of said right-of-ways (private) is left to the discretion of the owners of the development". The easement is currently to be utilized as a utility easement for water line connectivity between the two developments. The second, private easement within Monterrane Subdivision is not shown on the Parker Springs preliminary map. Staff recommends that the "50' R/W Dedication" to the Corn property shown on the preliminary map be labeled as "Future public 50' R/W Dedication" on the final plat.

Water is to be provided by Chatham County. The developer is extending the 12" water line from Bynum Ridge Road, along Mt. Gilead Church Road, to the subject property. See Sheet 3 of the preliminary map. Utility easements have been provided to the adjoining properties of Monterrane, Phase 1, Monterrane, Ph 3 (Farrington property), Corn and Cooper for future extensions of county water lines. The water line from Big Woods Road is to be extended along Hatley Road, westward, to the Cooper property which will then tie into Parker Springs and Monterrane providing a loop line.

Per Scott Mitchell, Soil Scientist, the overall slope range on individual lots is from “0% to 35%, with most lots falling in the 5% to 20% range”. During the sketch design discussion with the Planning Board, Grey Styers, attorney for the applicant, stated that the developer would provide additional erosion control requirements for builders and homeowners on individual lots.

Individual on-site or off-site wastewater systems are proposed for each lot. Sixteen (16) lots will require off-site systems. Per the soil scientist, 14 of the off-site systems will be located on the southern off-site field (adjacent to parcel 17440, Haw River Baptist Church property) with two (2) systems to be located on the northern off-site field (adjacent to parcels 72233, Davis property, and parcel 76246, Flynn property). The off-site septic areas will be owned by the respective lot owners. The final plat will show twenty (20) foot wide utility easements to provided access to the off-site systems. Per Anne Lowry, R. S. Environmental Health Program Coordinator, “The developer shall have one septic contractor install all supply line utilities for off site septic areas. The supply line utility shall also be inspected by Environmental Health during installation”. Thomas Boyce, Chatham County Soil Specialist, has reviewed the soil scientist report , attachment # 4, and found the information adequate for preliminary design. The soil scientist has provided system layouts for each on-site and off-site system. The soil report and layouts can be viewed on the Planning page of the county web site at www.co.chatham.nc.us, Rezoning and Subdivision Cases, 2008, Parker Springs, preliminary.

The cemetery identified at sketch approval is located on a lot to be designated as open / common space and will be maintained by the homeowners association. Staff met with the developer, soil scientist, and Jim and Bev Wiggins and Jane Pyle, Chatham County Historical Association, on the property to look at the cemetery site and old house site. The developer discussed with Ms. Pyle and the Wiggins suggested the manner of upkeep and maintenance of the site. Per Ms. Pyle’s records, members of the Ellington and Knight families are buried in the cemetery. The lot fronts on the public road and will be numbered on the final plat.

Parker’s Creek is a perennial flowing stream. The developer has voluntarily shown a 100 foot riparian buffer (each side of creek for a total of 200 feet – measured from top of bank landward) on the preliminary map. Staff recommends that the buffers be labeled water hazard setback / vegetative stream buffer on the final plat. At the time of sketch design approval, the WSIV-Protected Area watershed district required a 50 foot wide buffer. The adjacent property to the east, Cooper Family / Contentnea Creek, requested a zoning district change and a conditional use permit. Per the approved RA-90 CUD zoning / conditional use permit requirements for the request, the developer must also maintain a 100 foot per side setback / vegetative buffers along the portion of Parker’s Creek crossing their property. Scott Mitchell, Soil Scientist, field identified other intermittent streams and wetlands. See attachment 5. The intermittent streams will have a 50 foot wide, per side, water hazard setback / vegetative stream buffer. Lot lines go to the edge of the stream buffers. The buffer areas will be open space to be maintained by the homeowners association.

Re: Parker Springs

ISSUES FOR FURTHER DISCUSSION AND ANALYSIS – con’t

During the sketch design review, Grey Styers, attorney for the applicant, stated that the developer would provide a 25 foot wide tree protection buffer along the common boundary between the subject property and Monterrane Subdivision along with an additional 25 foot wide structure setback from the initial 25 foot wide undisturbed buffer (for a total of 50 feet). The tree protection buffer and setback buffer will be shown on the final plat. The cross hatched area shown on the preliminary map is the existing walking trail for Monterrane Subdivision.

Also, during the sketch design review, Mr. Styers, stated that the developer would provide the Planning Board a site plan at the preliminary review showing the locations of the proposed house sites. The proposed house sites are shown on the individual septic layout plan in the soil scientist report.

Other agency reviews and approvals as required for a preliminary plat review have been received as follows:

NCDOT	Road Plan Approval	January 4, 2008
NCDOT	Commercial Driveway Permit	January 4, 2008
NCDOT	Encroachment Agreement (12” DIP watermain-SR-1700)	January 10, 2008
NCDENR	Authorization to Construct Water line	December 17, 2007
CHATHAM COUNTY	Erosion Control Permit	December 18, 2007
U.S. ARMY CORPS OF ENGINEERS	Creek Crossing Permit	November 30, 2007
NCDWQ	401 Water Quality Permit	December 3, 2007

Copies of the above listed permits can be viewed on the Planning Department website at www.chathamnc.org under Planning, Rezoning & Subdivision Cases, 2008, Parker Springs, Prel.

The Chatham County Emergency Operations Office has approved the road names ‘Parker Springs Way’, ‘Adger Court’, and ‘Newcastle Court’. The preliminary map shows ‘Newcastle Court’ as the name of the main road. Emergency Operations requests that the main road name be ‘Parker Springs Way’ to reflect the subdivision name. This will be corrected on the final plat.

RECOMMENDATION: *The plat meets the requirements of the Subdivision Regulations with the final approvals of other agencies.* The Planning Department recommends granting approval of the road names ‘Parker Springs Way’, ‘Adger Court’, and ‘Newcastle Court’ and preliminary design approval with the following conditions:

1. The “60’ R/W Dedication” shown on the preliminary map between Lots 46 and 47 be changed to read “Future public 60’ R/W Dedication” on the final plat.
2. The “50’ R/W Dedication” to the Corn property shown on the preliminary map be labeled as “Future public 50’ R/W Dedication” on the final plat.

Re: Parker Springs

RECOMMENDATION – con't

3. The developer shall have one septic contractor install all supply line utilities for off site septic areas. The supply line utility shall also be inspected by Environmental Health during installation
4. The final plat shall show the 25 foot wide tree buffer along with the 25 foot wide structure setback (50 foot total) along the common boundary line with Monterrane Subdivision.
5. The main road name into the subdivision be changed to “Parker Springs Way” on the final plat.