



North Carolina Department of Environment and Natural Resources

Pat McCrory
Governor

Donald R. van der Vaart
Secretary

July 30, 2015

Mr. Charlie Horne, County Manager
Chatham County
12 East Street, Courthouse Annex
Pittsboro, North Carolina 27312

Re: Engineering Plans and Specifications Approval
Water Main Extension
Briar Chapel – Phase 15 North
Chatham County - North Water System
Water System No.: NC0319126, Chatham County
Serial No. 15-00550

Dear Mr. Horne:

Enclosed please find one copy of the "Application for Approval..." together with one copy of the referenced engineering plans and specifications bearing the Division of Water Resources stamp of approval for the referenced project. These engineering plans and specifications are approved under Division of Water Resources Serial Number 15-00550, dated July 30, 2015.

Engineering plans and specifications prepared by Gareth C. Avant, P.E., call for the installation of approximately 1,790 feet of 8-inch and 680 feet of 6-inch water main, valves, hydrants and other appurtenances along Boulder Point Drive, west of the intersection with Briar Chapel Parkway.

Please note that in accordance with 15A NCAC 18C .0309(a), no construction, alteration, or expansion of a water system shall be placed into service or made available for human consumption until the Public Water Supply Section has issued Final Approval. Final Approval will be issued and mailed to the applicant upon receipt of both an Engineer's Certification and an Applicant's Certification submitted in accordance 15 A NCAC 18C .0303 (a) and (c).

These plans and specifications in the foregoing application are approved insofar as the protection of public health is concerned as provided in the rules, standards and criteria adopted under the authority of Chapter 130A-317 of the General Statutes. This approval does not constitute a warranty of the design, construction or future operation of the water system.

Mr. Charlie Horne, County Manager

Page 2 of 2

July 30, 2015

One copy of the "Application for Approval..." and a copy of the plans and specifications with a seal of approval from the department are enclosed. One copy of the enclosed documents is being forwarded to our Raleigh Regional Office. The third copy is being retained in our files.

If the Public Water Supply Section can be of further service, please call (919) 707-9100.

Sincerely,



Robert W. Midgette, P.E., Operations Branch Head
Public Water Supply Section
Division of Water Resources

RWM/LAQ

Enclosures: Approval Documents

cc: Allen Hardy, Raleigh Regional Office
Chatham County Health Department
Gareth C. Avant, P.E., McKim & Creed, Inc.