

Mark Ashness

From: Dan LaMontagne <dan.lamontagne@chathamnc.org>
Sent: Wednesday, February 04, 2015 3:46 PM
To: Mark Ashness
Cc: Lynn Richardson
Subject: RE: Legacy Phase 4A and 5A

That is correct. You are good to go.

Dan J. LaMontagne, P.E.
Public Works Director
Chatham County
919-545-8531

In keeping with the NC Public Records Law, e-mails, including attachments, may be released to others upon request for inspection and copying.

From: Mark Ashness [<mailto:mark@cegroupinc.com>]
Sent: Tuesday, February 03, 2015 2:41 PM
To: Dan LaMontagne
Subject: Legacy Phase 4A and 5A

Dan: Just a heads up. We are submitting for Prel plat on Legacy Phase 4A on Friday. Phase 5A will be next month.

This project pre-dates the County stormwater ordinance. We do have wet or dry stormwater controls at all release points handling the first ½" of impervious (with a 2-5 day drawdown). The submission we made to you (attached) on Dec 17th has all that info.

When we spoke last week you were going to let Lynn know that we were good. I am just confirming that this is the case.

thx

Mark Ashness
P.E, ASLA, LEED AP



301 Glenwood Avenue, Suite 220
Raleigh, NC 27603
Phone: (919) 367-8790
Cell: (919) 606-7704