



	Approved	Denied
Date Action Taken:	9/10/07	
Other:		
Verified by:	<i>W. Miller</i>	

WASILLA CITY COUNCIL ACTION MEMORANDUM

AM No. 07-53

TITLE: AWARD OF CONTRACT TO FERGUSON ENTERPRISES, INC., IN AN AMOUNT NOT TO EXCEED \$50,000 FOR HIGH HEAD DEWATERING PUMPS.

Agenda of: September 10, 2007

Date: August 20, 2007

Originator: William A. Miller, Purchasing Officer

Route to:	Department	Signature/Date
	Police Chief Youth Court, Dispatch, Code Compliance	
	Culture and Recreation Services Director Library, Museum, Sports Complex	
	Public Works & Recreation Facility Maintenance Director	
X	Finance, Risk Management & MIS Director Purchasing	<i>Dianne M. Keller 8-31-07</i>
X	Deputy Administrator Planning, Economic Development, Human Resources	<i>Sandra Kelly</i> <i>W.A.M.</i>
X	City Clerk	

REVIEWED BY MAYOR DIANNE M. KELLER: *Sandra Kelly for the Mayor*

FISCAL IMPACT: yes \$50,000 or no Funds Available yes no
 Account name/number: \$50,000 310-4353-435.60-99 Sewer Division - Inventory
 Attachments: Bid Abstract – Invitation to Bid #0674-0-2008/WM

SUMMARY STATEMENT: In accordance with WMC 5.08.110, on July 24, 2007, the City of Wasilla issued Invitation to Bid 0674-0-2007 for the provision of high head dewatering pumps for the pumping of sewage. Bids were received from the following firms: Alaska Pump & Supply of Anchorage, Alaska Roteq of Wasilla, Delta-P Pump & Equipment of Eagle River, Ferguson Enterprises of Wasilla and National Oilwell Varco of Anchorage. Following a thorough review of the bids, the Purchasing/Contracting Officer confirmed that all of them with the exception of the Alaska Roteq bid conformed in all material respects to the solicitation. The Alaska Roteq bid was not submitted on a bid sheet but as a "quotation" which was not allowed per the solicitation thus it was deemed non-responsive.

Of the responsive and responsible bids received, Ferguson Enterprises of Wasilla was the low cost bidder (see attached).

SPECIFICATIONS FOR SUBMERSIBLE PUMPS:

The City of Wasilla is seeking to secure high-head dewatering pumps for the Department of Public Works – Waste Water Division. Deliveries are to be FOB Wasilla. The final destination of all pumps ordered will be the City of Wasilla Sewer Plant located at 2900 Jude Street, Wasilla, Alaska 99654.

Pump #1: 240 volt single-phase, double-sealed, continuous run submersible effluent pumps capable of delivering 10 gallons per minute at a total dynamic head of 72 feet. 20' cord minimum.

Pump #2: 240 volt single-phase, double-sealed, continuous run submersible effluent pumps capable of delivering 10 gallons per minute at a total dynamic head of 102 feet. 20' cord minimum.

ACTION: Council is requested to authorize the award of a contract for high head dewatering pumps to Ferguson Enterprises, Inc., in an amount not to exceed \$50,000 for FY2008.



CITY OF WASILLA

• Purchasing •

290 East Herring Avenue • Wasilla • Alaska • 99654-7091
• Telephone 907-373-9047 • Fax 907-373-9011 •

Abstract of Bids Received for Bid #: ITB-0674-0-2008/WM

Title: High-head Dewatering Pumps

Date: August 17, 2007 Time: 2:01 p.m. Location: Wasilla City Hall – Public Works

	Alaska Pump & Supply	Alaska Roteq	Alfred Conhagen	Delta P Pump & Equip., LLC	Ferguson Ent.	Godwin Pumps of America, Inc.	National Oilwell Varco	Northwest Pump & Equip.	Premier Pump Company	Quality Equip. Sales & Service	USA Blue Book
Date Received:	8/17/07	8/16/07	8/17/07	8/17/07	8/10/07	8/9/07					
Fifty (50) each - 240 volt single-phase, double-sealed, continuous run submersible effluent pumps capable of delivering 10 gallons per minute at a total dynamic head of 72 feet. 20' cord minimum. Cost of per pump FOB Wasilla:	\$540.00 Myers P52	N O N R E S P O N S I V E B I D	N O B I D R E C E I V E D	\$935.00 Zoeller E810	\$525.07 Myers P52	N O B I D R E C E I V E D	\$622.85 Myers P52	N O B I D R E C E I V E D	N O B I D R E C E I V E D	N O B I D R E C E I V E D	N O B I D R E C E I V E D
Twenty-five (25) each - 240 volt single-phase, double-sealed, continuous run submersible effluent pumps capable of delivering 10 gallons per minute at a total dynamic head of 102 feet. 20' cord minimum. Cost of per pump FOB Wasilla:	\$620.00 Myers P102			\$935.00 Zoeller E810	\$609.66 Myers P102		\$746.29 Myers P102				
Local Bidder Preference per WMC 5.08.190 (2.5%)	NO			NO	YES		NO				
Award Bid To:					X						

Note: The Alaska Roteq Corporation bid was deemed non-responsive as it was not on a City of Wasilla bid document obtained from the City of Wasilla as outlined on page one (1) and two (2) of the bid document.

Bid Opening Attendance Record

Company Name	Company Representative	Telephone Number	E-mail Address
City of Wasilla	Bill Miller	907-373-9047	wmiller@ci.wasilla.ak.us
City of Wasilla	Sandra Connolly	907-737-9017	sconnolly@ci.wasilla.ak.us
City of Wasilla Library	KJ Martin-Albright	907-376-5913	kmartin@ci.wasilla.ak.us