

Requested by: Public Works  
Prepared by: Public Works  
Introduced: February 11, 2002  
Public Hearing: February 25, 2002  
Adopted: February 25, 2002  
Vote: Unanimous

**CITY OF WASILLA  
ORDINANCE SERIAL NO. 02-07**

**AN ORDINANCE OF THE CITY OF WASILLA AMENDING THE FY-02 BUDGET BY  
APPROPRIATING FUNDS TO THE WATER ENTERPRISE FUND FOR EMERGENCY  
REPAIRS TO THE RICHMOND HILLS BOOSTER STATION.**

**Section 1. Classification.** This is a non-code ordinance.

**Section 2. Purpose.** To appropriate funds within the General Fund for the purpose of repairing the Richmond Hills Booster Station.

**Section 3. Appropriation.** Funds are appropriated to the following fund:

Water Enterprise Fund


32-53-620-491-00 Other Contractual Services \$30,000

**Section 4. Source of Funds.**


Capital Reserve \$30,000

**Section 5. Effective Date.** This ordinance becomes effective upon adoption by the Wasilla City Council.


ADOPTED by the Wasilla City Council on February 25, 2002

  
SARAH PALIN, Mayor

ATTEST:

  
KRISTIE L. VANGORDER, CMC  
City Clerk

[SEAL]



**CITY OF WASILLA**  
290 E. HERNING AVE.  
WASILLA, AK 99654-7091  
PHONE: (907) 373-9090  
FAX: (907) 373-9092

---

TO: Wasilla City Council  
THRU: Mayor Sarah Palin *SP*  
FROM: Public Works  
DATE: February 5, 2002  
**SUBJECT: Ordinance Serial No. 02-07**

---

**SUMMARY:** The Richmond Hills Booster Station has recently experienced a failure in some of the electrical equipment. This booster station supplies water along the east Parks Highway to Wal-Mart and other businesses. The failure has caused the fire flow pump to be inoperable. The smaller pumps are still functioning and they provide limited fire flow capacity. The new equipment is required to be compatible with the existing equipment, and therefore, the equipment will be purchased without a competitive bid. Staff have researched purchase options and have verified the best possible price is being obtained.

The two main parts needed will cost approximately \$18,000.00. Additional parts may be needed along with cost of installation. In addition, the design engineer is being consulted to determine the cause of the problem, propose a fix if necessary, and provide documentation that will enable the City to pursue a possible warrantee of the failed electrical equipment.

**FISCAL IMPACT:** If yes, amount requested: \$30,000  
Account No.: 32-53-620-491-00

**RECOMMENDED ACTION:** Council is requested to adopt Ordinance Serial No. 02-07 to provide funding to repair the Richmond Hills Booster Station.